



Bender UK Ltd.

Low Mill Business Park, Ulverston • Cumbria LA 12 9 EE
Tel.: 01229 480 123 • Fax: 01229 480 345
info@bender-uk.com • www.bender-uk.com



UK - Declaration of Conformity

Manufacturer: **Bender GmbH & Co. KG**

declare under our sole responsibility that the product

Product name: **Insulation monitoring device isoGEN4xx (see annex)**

to which this declaration relates, is in conformity with the following UK legislations.


Legislations:	RoHS Regulations 2012	S.I. 2012:3032
	Radio Equipment Regulations 2017	S.I. 2017:1206

The assessment of this product has been based on the following standards:

Applied standards :

EN 61557-8	:2015/AC:2016
EN IEC 61326-2-4	:2021
EN IEC 61557-1	:2021/A1:2024
EN IEC 63000	:2018
ETSI EN 301 489-3	V2.3.2 (2023-01)

Gruenberg, 15.09.2026



(Alexander Doerr, Product Validation)

Remark:

The annexes are part of this UK declaration.
Limitation of standards are marked with an asterisk (*) in the attached type list.



Bender UK Ltd.

Low Mill Business Park, Ulverston • Cumbria LA 12 9 EE
Tel.: 01229 480 123 • Fax: 01229 480 345
info@bender-uk.com • www.bender-uk.com



Annex - Typelist of UKCA-declaration isoGEN4xx

Product group	Art.-no.	Device type
isoGEN4xx	B81674000	isoGEN413R-1 3(N)AC, AC, DC 0...400 V